

CITY OF SIOUX CITY, IOWA

UTILITIES DIVISION -- SEWER SERVICE REPORT

X MAIN BACKUP PRIVATE SERVICE BACKUP SEWER GAS

1. Complaint Address 11 BLACKSTONE
(House or Building Address)
2. Did an SSO occur YES (If yes complete an SSO Report)
3. Received - Date 4 JAN 16 Time 1:30 pm
4. Arrived at Place - Date 4 JAN 16 Time 2:00 pm
5. Depth of Sewage in Basement 1/4"
6. Caused by City Main yes
7. Caused by Private Sewer Service No
8. Location of Plug (if main) 100 ft S of MHE STONE PARK + BLACKSTONE
9. Cause of Plug PIPE collapse
10. Apparent Damage: (Furnace) (Water Heater) (Washer) (Dryer) (Other)

Contents: Carpet

11. Was Basement Cleaned by City Crews? No JAYZ RESTORATION
12. Were Occupants Satisfied? yes
13. Additional Information Coming in on 5th Jan to dig up pipe
Flows going through so there should not be a issue
for the night

14. Reported by DeHary Title Utility worker

Date 4 Jan 16

CITY OF SIOUX CITY
FIELD SERVICES-UTILITIES
1921 18TH ST, SIOUX CITY, IA 51105

SSO REPORT

X PUBLIC PRIVATE

LOCATION OF INCIDENT: # 11 Blackstone

REPORTED BY: DeHaert DATE: 4 Jan 18 TIME: 7pm

SENT TO (IDNR STAFF NAME): Tom Rajs (EMAIL, PHONE, FAX)

SSO START DATE: 4 Jan 18 SSO START TIME: 1:30pm

SSO STOP DATE: 4 Jan 18 SSO STOP TIME: 6:00pm

ESTIMATED VOLUME (IN GALLONS): 5 Gals

CONTENTS OF SSO: Sewage

REASON FOR SSO: Pipe collapse

DID THE SSO REACH THE STORM SYSTEM: No

IF YES, LOCATION OF OUTLET (NAME OF WATERBODY): n/a

DISTANCE TRAVELED ON SURFACE: 4ft radius around drain

DISTANCE TRAVELED IN STORM SYSTEM TO OUTLET: —

ACTION TAKEN TO STOP SSO: Jet line, going to repair pipe to

PLANNED ACTION TO PREVENT FUTURE SSO (IF POSSIBLE):

SAMPLING REQUIRED: — LOCATION OF SAMPLES: —

ADDITIONAL COMMENTS: